



Mathews County Building Department

50 Brickbat Rd. Mathews VA 23109

(804) 725-7171 <https://www.mathewscountyva.gov/>

Temporary Electrical Service Policy

If a permit is issued for temporary electrical service, the following shall apply:

- All work must comply with the Virginia USBC, the NEC (NFPA 70) and Dominion Energy requirements
- An inspection must be performed per the Required Inspections List
- Temporary Service shall only be granted for a specific use and specified time period
- Temporary Service will be disconnected, when any of the following occurs:

The time period expires

The permit expires or is revoked

The service is being used contrary to the permitted use

Any unsafe conditions are discovered

Note: eventually all temporary electrical service installations must be disconnected